



GENERAL NOTES:

1. REU ENGINEERING WILL SPOT THE SERVICE LOCATION AT TRAILER/DOUBLE-WIDE.
2. SERVICE DROP CLEARANCES SHALL BE AS FOLLOWS:
 - IN GENERAL - 12 FEET
 - DRIVEWAYS - 16.5 FEET
 - ROADS - 18 FEET
3. SERVICE ENTRANCE SHALL COMPLY WITH ALL REU SPECIFICATIONS AND MUST PASS ELECTRICAL INSPECTION.
4. EXTEND SERVICE ENTRANCE CONDUCTORS 18" MINIMUM OUT WEATHERHEAD. CLEARLY IDENTIFY PHASE & NEUTRAL CONDUCTORS.

PREPARED BY:	KDB	SPECIFICATION FOR OVERHEAD SERVICE MOBILE HOMES, TRAILERS & MANUFACTURED HOMES	SCALE: NONE	
CHECKED BY:	JD		DRAWING NUMBER	REV.
APPROVED BY:	KDB		OHS-	0
ROCKWOOD ELECTRIC UTILITY 341 W. ROCKWOOD ST. ROCKWOOD, TN 37854		002		